

875—93.8(89) Blowoff. Miniature power boilers shall be equipped with a blowoff connection, not less than ½-inch pipe size, located to drain from the lowest water space practicable. The blowoff shall be equipped with a valve or cock not less than ½-inch pipe size.

[ARC 8283B, IAB 11/18/09, effective 1/1/10]